



2013002533A

检验编号: MT2015-0803

Reference No.:

检 验 报 告

Test Report

试 样 名 称 不锈钢无卤金属软管用塑料

Name of product: Plastic for HalogenFree Metal Flexible Conduit

型 号 规 格 MCRHF

Type and size:

委 托 单 位 上海日成电子有限公司

Client: SHANGHAI RICHENG ELECTRONICS CO., LTD

检 验 类 别 委托检验

Kind of test: Customer-ordered test

机械工业电工材料及特种线缆产品质量监督检测中心

MACHINERY INDUSTRY QUALITY SUPERVISION AND TEST CENTER
FOR ELECTRICAL MATERIAL AND SPECIAL WIRE & CABLE



机械工业电工材料及特种线缆产品质量监督检测中心

MACHINERY INDUSTRY QUALITY SUPERVISION AND TEST CENTER
FOR ELECTRICAL MATERIAL AND SPECIAL WIRE & CABLE

检 验 报 告

Test Report

第1页 共3页

1 of 3

试样名称 Name of product	不锈钢无卤金属软管用塑料 Plastic for HalogenFree Metal Flexible Conduit						
型号规格 Type and size	MCRHF		状态描述 Sample Description	黑色片状, 符合测试要求 Black sheet, meet the requirements of test			
检验类别 Kind of test	委托检验 Customer-ordered test		检验编号 Reference No.	MT2015-0803			
委托单位 Client	上海日成电子有限公司 SHANGHAI RICHENG ELECTRONICS CO., LTD		地 址 Address	上海奉贤区柘林镇新中工业区新林路950号 XINLIN ROAD 950, XINSHENG INDUSTRIAL AREA, ZHELIN, FENGXIAN, SHANGHAI			
生产单位 Producer	上海日成电子有限公司 SHANGHAI RICHENG ELECTRONICS CO., LTD		到样日期 Date of receipt	2015. 05. 28			
取样方式 Delivering method	自送 Sample delivered by customer	送样人 Deliverer	张锦烽 Zhang Jinfeng	邮政编码 Zip code	200327	电话号码 Tel	64893666
检验依据 Test standard	上海日成电子有限公司提供的技术条件 The technical specification offered by "SHANGHAI RICHENG ELECTRONICS CO., LTD" ASTM E662-2015 Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials,						
检验日期 Test date	2015. 05. 28 — 2015. 05. 29						
检验结论 Conclusion	来样所测1项性能符合上海日成电子有限公司提供的技术条件要求。 The one property of the specimen meets the requirement of the technical specification provided by "SHANGHAI RICHENG ELECTRONICS CO., LTD".						
备 注 Remarks	试样厚度: 有焰 0.58mm; 无焰 0.80mm Specimen thickness: Flaming 0.58mm; Non-flaming 0.80mm						
编 写 Edit	丁晓青		审 核 Review	毛伟杰		批 准 Approval	张永杰
日 期 Date	2015. 5. 29		日 期 Date	2015. 5. 29		日 期 Date	2015-5-29


试样型号和规格: Type and size:		MCRHF	检验编号: Reference No.:		MT2015-0803
序号 No.	检 验 项 目 Item of test	单位 Unit	标准要求 Requirement	检验结果 Test result	单项判定 Judgement
1	烟密度 Specific Optical Density of Smoke				
1.1	有焰 Flaming				
	D _s (90s)	—	≤100	63	√
	D _s (240s)	—	≤200	113	√
1.2	无焰 Non-flaming				
	D _s (90s)	—	≤100	31	√
	D _s (240s)	—	≤200	119	√
	—以下空白— —End of report—				
注: “√”表示该项目合格, “×”表示该项目不合格。 Note: “√” means that the item is qualified, “×” means that the item is unqualified.					



试样型号和规格:
Type and size:

MCRHF

检验编号: MT2015-0803
Reference No.:



原始试样
Original sample

