

SHANGHAI RICHENG ELECTRONICS CO., LTD
SHANGHAI OLD HUMIN ROAD CHINA

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description: WIRING DUCT

SGS Ref No.: 10358624

Test Requested:

ASTM E662:2003 Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials

Test Results: --- See attached sheet ---

Test Period:

Sample Receiving Date : AUG.13, 2010

Test Performing Date : AUG.13, 2010 TO AUG.19, 2010

Signed for and on behalf of
SGS-CSTC Co., Ltd.



Allen Zou
Technical Supervisor

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its inspection only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



AJHG 165792

I. Test conducted

This test is conducted according to ASTM E662:2003 Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials

II. Sample details

Description	Wiring Duct
Color	Gray
Dimensions	75 mm×75 mm×1.8mm
Condition prior to testing	Prior to testing, the wiring duct , dried for 24 h at 60±3°C and then 23±3°C and RH 55±5% till constant weight
Irradiance Exposure	2.50±0.05 W/cm ²

III. Test results

1) Flaming mode

	Test Specimen			Flaming dripping or flaming running	Average Optical density
	#1	#2	#3		
Temperature of chamber wall (°C)	33	33	34	Flaming running	
$D_{S 1.5}$	426	418	435		426.3
$D_{S 4.0}$	652	630	615		632.3
D_m	662	650	658		656.7
t_{D_m}	260	285	280		
$Dm(corr)$	160	110	98		122.7
Observations	Color of the smoke black				

加上单位

To be continued...

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its inspection only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



AJHG 165793

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755)83071443, or email: CN.Doccheck@sgs.com

2) Non - Flaming mode

	Test Specimen			Flaming dripping or flaming running	Average Optical density
	#1	#2	#3		
Temperature of chamber wall (°C)	33	33	34	NO	
$D_{S 1.5}$	18	32	21		23.7
$D_{S 4.0}$	189	195	201		195.0
D_m	457	425	438		440
t_{D_m}	730	750	720		
$Dm(corr)$	23	18	20		20.3
Observations	Color of the smoke black				

Note:

→ 加上单位

$D_{S 1.5}$ = Specific optical density at 1.5 minutes;

$D_{S 4.0}$ = Specific optical density at 4.0 minutes;

D_m = maximum specific optical density;

$Dm(corr)$ = corrected D_m , $Dm(corr) = D_m - D_c$

t_{D_m} = time of D_m occurrence

STATEMENTS:

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

The test results relate only to the specimens of the product in the form in which were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimens, which were tested.

The specimen was supplied by the sponsor and SGS-CSTC ANJI Branch was not involved in any selection or sampling procedure.

To be continued....

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its issue and is valid only within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.



AJHG 165794

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755)83071443, or email: CN.Doccheck@sgs.com

Photo Appendix:



End of Report

Attention: To check the authenticity of testing/inspection report & certificate, please contact us at telephone: (86-759)83071443, or email: CN.Doccheck@sgs.com

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.htm and for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, the jurisdiction and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its inspection only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

